

CITY OF AUSTIN STANDARD PRODUCTS LIST

for

WASTEWATER MANHOLE INTERNAL DROP

USING DEPARTMENT: Austin Water PREPARED BY: Jeff A. Kyle P.E. ISSUED: 07/01/19

REVISED BY: REVISED:

DESCRIPTION:

Internal drop for wastewater manholes, consisting of a fiberglass reinforced polyester resin bowl in combination with PVC drop pipe, meeting the following requirements:

- 1. Bowl shall be secured to manhole wall using manufacturer-provided anchor bolt assembly.
- 2. Drop pipe shall be ASTM D3034 SDR35 pipe secured to the manhole wall using manufacturer-provided adjustable brackets, nuts, bolts, washers, and anchor bolt assembly.
- 3. Brackets shall be at least 11 gauge thick, 316 stainless steel.
- 4. Nuts. bolts. and washers shall be 18-8 stainless steel.
- 5. Each anchor bolt assembly shall consist of an 18-8 stainless steel bolt and washer and zinc alloy lead anchor.
- 6. Stainless steel bracket extensions shall be provided as necessary where the manhole ID changes.

| LISTING DATE | MANUFACTURER | PRODUCT IDENTIFICATION/COMMENT | APPROVAL |
|-----------------|---|--|----------|
| 07/01/19 | DURAN, INC. 53 Mt. Archer Road Lyme, CT 06731 | RELINER drop bowel, with drop bowel installation anchor bolt assembly and drop pipe installation adjustable brackets and hardware | J. Kyle |

NOTES

1. Bowl shall be joined to drop pipe using a semi-rigid pipe coupler (SPL WW-354).

LATEST REVISIONS: