



**CITY OF AUSTIN  
STANDARD PRODUCTS LIST  
for  
TRACER TAPE**

**USING DEPARTMENT:** Austin Water      **PREPARED BY:** David Rinn      **ISSUED:** 01/26/99  
**REVISED BY:** Jeff A. Kyle, P.E.      **REVISED:** 07/01/21

**DESCRIPTION:** Tape, locating, inductive, detectable, 5 mil minimum overall thickness and 0.34 mil minimum thickness solid aluminum foil core. All brands shall be a minimum of 12" wide. The tape shall be color-coded: blue for potable water, purple for reclaimed water, green for gravity wastewater, and brown for pressurized wastewater force main.

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
01/26/99	PRO-LINE SAFETY PRODUCTS CO. 1099 Atlantic Drive, Unit #1 West Chicago, IL 60185		D. Rinn
07/01/13	DALIAN METALS I/E, CO. LTD. (China) ACCUCAST 415 S. 21 <sup>st</sup> Street Waco, TX 76706		R. Lamb
04/01/21	PRESCO PRODUCTS 1201 E. Pecan Street Sherman, TX 75090		J. Kyle
07/01/21	TRINITY TAPE & MARKING, LLC 3573 Bennett Road Howe, TX 75459		J. Kyle

**NOTES:**

- Tracer Tape shall be placed in the same trench, located parallel to and directly above the centerline of the pipe.
- Tracer Tape shall be laid a minimum of 12" below subgrade and no deeper than 36". In areas outside the limits of pavement, Tracer Tape shall be laid a minimum of 18" below finished grade and no deeper than 36".
- Tracer Tape for pressurized wastewater force main must bear the label 'PRESSURIZED WASTEWATER' continuously repeated in at least 1.5" tall letters.

**LATEST REVISIONS (since 04/01/21):**

- Added brown tape color-code for wastewater force main.
- Added NOTES 1, 2, and 3.
- Added TRINITY TAPE & MARKING, LLC.