

Drinking Water Quality Report
Date Range: 01-AUG-2018 to 31-AUG-2018

Parameter	Units	Method Cd		Davis WTP T2,T2H		Ullrich WTP T3		WTP 4 T4
-----	----	-----		-----		-----		-----
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.7	AVG	9.7
			MAX	9.8	MAX	9.8	MAX	9.8
			MIN	9.5	MIN	9.5	MIN	9.6
Total Alkalinity	MG/L	SM 2320 B	AVG	68	AVG	60	AVG	64
			MAX	75	MAX	62	MAX	69
			MIN	62	MIN	56	MIN	60
Total Hardness	MG/L	SM 2340 C	AVG	91	AVG	84	AVG	84
			MAX	97	MAX	86	MAX	90
			MIN	84	MIN	79	MIN	80
Total Solids	MG/L	SM 2540 B	AVG	152	AVG	151	AVG	164
			MAX	180	MAX	180	MAX	200
			MIN	122	MIN	118	MIN	128
Chloramines	MG/L	SM 4500-CL F	AVG	2.85	AVG	2.75	AVG	2.80
			MAX	3.05	MAX	3.00	MAX	3.00
			MIN	2.70	MIN	2.00	MIN	2.55
Sulfate	MG/L	SM 4500-SO4 E	AVG	33.5	AVG	33.1	AVG	33.0
			MAX	34.1	MAX	33.1	MAX	33.0
			MIN	32.9	MIN	33.1	MIN	33.0
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.69	AVG	2.43	AVG	2.40
			MAX	2.94	MAX	2.58	MAX	2.58
			MIN	2.52	MIN	2.32	MIN	2.30
Conductivity	UMHOS/cm	SM 2510 B	AVG	299	AVG	288	AVG	326
			MAX	302	MAX	288	MAX	326
			MIN	295	MIN	288	MIN	326
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	30.3	AVG	21.5	AVG	27.5
			MAX	34.3	MAX	27.3	MAX	32.6
			MIN	26.7	MIN	19.4	MIN	22.2
Turbidity	NTU	SM 2130 B	AVG	0.05	AVG	0.02	AVG	0.03
			MAX	0.08	MAX	0.04	MAX	0.04
			MIN	0.03	MIN	0.02	MIN	0.02