

Drinking Water Quality Report
Date Range: 01-AUG-2017 to 31-AUG-2017

Parameter	Units	Method Cd		Davis WTP		Ullrich WTP		WTP 4
-----	----	-----		T2,T2H		T3		T4
				-----	-----	-----	-----	-----
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.6	AVG	9.6
			MAX	9.8	MAX	9.7	MAX	9.8
			MIN	9.5	MIN	9.5	MIN	9.6
Total Alkalinity	MG/L	SM 2320 B	AVG	57	AVG	55	AVG	63
			MAX	60	MAX	61	MAX	66
			MIN	51	MIN	48	MIN	61
Total Hardness	MG/L	SM 2340 C	AVG	79	AVG	80	AVG	82
			MAX	83	MAX	84	MAX	86
			MIN	75	MIN	74	MIN	78
Total Solids	MG/L	SM 2540 B	AVG	130	AVG	124	AVG	152
			MAX	142	MAX	130	MAX	159
			MIN	116	MIN	120	MIN	144
Chloramines	MG/L	SM 4500-CL F	AVG	2.88	AVG	2.75	AVG	2.77
			MAX	3.10	MAX	3.10	MAX	3.00
			MIN	2.70	MIN	2.40	MIN	2.65
Sulfate	MG/L	SM 4500-SO4 E	AVG	31.0	AVG	28.0	AVG	29.0
			MAX	31.1	MAX	28.3	MAX	28.9
			MIN	30.3	MIN	28.3	MIN	28.9
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.79	AVG	2.67	AVG	2.74
			MAX	3.12	MAX	2.85	MAX	2.88
			MIN	2.54	MIN	2.48	MIN	2.66
Conductivity	UMHOS/cm	SM 2510 B	AVG	265	AVG	268	AVG	302
			MAX	268	MAX	268	MAX	302
			MIN	262	MIN	268	MIN	302
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	38.6	AVG	40.6	AVG	32.4
			MAX	48.7	MAX	43.3	MAX	34.0
			MIN	33.4	MIN	35.6	MIN	30.7
Turbidity	NTU	SM 2130 B	AVG	0.05	AVG	0.03	AVG	0.04
			MAX	0.10	MAX	0.03	MAX	0.07
			MIN	0.03	MIN	0.02	MIN	0.03