

Drinking Water Quality Report  
Date Range: 01-APR-2018 to 30-APR-2018

Parameter	Units	Method Cd	Davis WTP		Ullrich WTP		WTP 4	
				T2,T2H		T3		T4
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.6	AVG	9.6
			MAX	9.7	MAX	9.8	MAX	9.7
			MIN	9.6	MIN	9.5	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	56	AVG	59	AVG	74
			MAX	60	MAX	64	MAX	78
			MIN	52	MIN	54	MIN	72
Total Hardness	MG/L	SM 2340 C	AVG	84	AVG	89	AVG	94
			MAX	89	MAX	94	MAX	98
			MIN	79	MIN	83	MIN	91
Total Solids	MG/L	SM 2540 B	AVG	152	AVG	164	AVG	165
			MAX	186	MAX	188	MAX	198
			MIN	132	MIN	146	MIN	150
Chloramines	MG/L	SM 4500-CL F	AVG	2.62	AVG	2.48	AVG	2.61
			MAX	2.75	MAX	2.65	MAX	2.75
			MIN	2.50	MIN	2.20	MIN	2.45
Sulfate	MG/L	SM 4500-SO4 E	AVG	12.3	AVG	33.9	AVG	26.4
			MAX	13.4	MAX	33.9	MAX	26.4
			MIN	11.1	MIN	33.9	MIN	26.4
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.57	AVG	2.63	AVG	2.69
			MAX	2.74	MAX	2.76	MAX	2.79
			MIN	2.43	MIN	2.50	MIN	2.62
Conductivity	UMHOS/cm	SM 2510 B	AVG	289	AVG	298	AVG	322
			MAX	295	MAX	299	MAX	325
			MIN	280	MIN	296	MIN	319
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	35.4	AVG	36.5	AVG	30.3
			MAX	36.9	MAX	37.7	MAX	33.0
			MIN	34.0	MIN	35.0	MIN	27.7
Turbidity	NTU	SM 2130 B	AVG	0.04	AVG	0.04	AVG	0.03
			MAX	0.07	MAX	0.06	MAX	0.05
			MIN	0.02	MIN	0.03	MIN	0.02