

Drinking Water Quality Report
Date Range: 01-MAR-2018 to 31-MAR-2018

Parameter	Units	Method Cd	Davis WTP		Ullrich WTP		WTP 4	
				T2,T2H		T3		T4
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.6	AVG	9.6
			MAX	9.8	MAX	10.1	MAX	9.7
			MIN	9.4	MIN	9.2	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	62	AVG	63	AVG	75
			MAX	67	MAX	85	MAX	80
			MIN	53	MIN	55	MIN	70
Total Hardness	MG/L	SM 2340 C	AVG	89	AVG	91	AVG	94
			MAX	94	MAX	112	MAX	100
			MIN	79	MIN	85	MIN	90
Total Solids	MG/L	SM 2540 B	AVG	139	AVG	145	AVG	159
			MAX	150	MAX	156	MAX	178
			MIN	126	MIN	126	MIN	140
Chloramines	MG/L	SM 4500-CL F	AVG	2.68	AVG	2.55	AVG	2.55
			MAX	2.80	MAX	2.80	MAX	2.65
			MIN	2.50	MIN	2.35	MIN	2.40
Sulfate	MG/L	SM 4500-SO4 E	AVG	37.8	AVG	37.4	AVG	25.7
			MAX	37.8	MAX	37.4	MAX	25.7
			MIN	37.7	MIN	37.4	MIN	25.7
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.57	AVG	2.59	AVG	2.69
			MAX	2.72	MAX	2.76	MAX	2.83
			MIN	2.40	MIN	2.49	MIN	2.59
Conductivity	UMHOS/cm	SM 2510 B	AVG	296	AVG	295	AVG	319
			MAX	297	MAX	295	MAX	319
			MIN	295	MIN	295	MIN	319
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	28.6	AVG	31.5	AVG	26.3
			MAX	31.8	MAX	32.9	MAX	27.1
			MIN	26.3	MIN	28.9	MIN	25.7
Turbidity	NTU	SM 2130 B	AVG	0.05	AVG	0.03	AVG	0.03
			MAX	0.07	MAX	0.24	MAX	0.05
			MIN	0.02	MIN	0.03	MIN	0.02